



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02728

Received Date: 07/20/2021
Reported Date: 07/29/2021
Sampled By: Andrew Theal
Tech Certification #:

Project/Test Address: 2020L-148.1; High School; 1901 Sweet Home Rd; Buffalo, NY 14228

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02728-001	148.1-21	07/01/2021	BOILER ROOM	26.6	07/27/2021	
21-07-02728-002	148.1-63	07/01/2021	WOMANS COACH'S OFFICE	10.6	07/27/2021	
21-07-02728-003	148.1-67	07/01/2021	BOYS PHYS ED LOCKER ROOM 518 WEST	6.13	07/27/2021	
21-07-02728-004	148.1-70	07/01/2021	BOYS VISITOR LOCKER ROOM 520 LEFT	16.6	07/27/2021	
21-07-02728-005	148.1-71	07/01/2021	BOYS VISITOR LOCKER ROOM 520 RIGHT	54.6	07/27/2021	
21-07-02728-006	148.1-72	07/01/2021	LAUNDRY ROOM SINK	20.4	07/27/2021	
21-07-02728-007	148.1-97	07/01/2021	GIRLS LAV 300 RIGHT MOST	21.9	07/27/2021	
21-07-02728-008	148.1-98	07/01/2021	MENS FACULTY LAV 200 LEFT	37.2	07/27/2021	
21-07-02728-009	148.1-99	07/01/2021	MENS FACULTY LAV 200 RIGHT	25.7	07/27/2021	
21-07-02728-010	148.1-101	07/01/2021	WOMENS FACULTY LAV 200 CENTER	12.4	07/27/2021	
21-07-02728-011	148.1-205	07/01/2021	ROOM 716 KITCHENETTE	39.8	07/27/2021	
21-07-02728-012	148.1-207	07/01/2021	WOMENS FACULTY LAV 700 LEFT	146	07/27/2021	
21-07-02728-013	148.1-208	07/01/2021	WOMENS FACULTY LAV 700 LEFT CENTER	80.9	07/27/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-07-02728

Project/Test Address: 2020L-148.1; High School; 1901 Sweet Home Rd;
Buffalo, NY 14228

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02728-014	148.1-209	07/01/2021	WOMENS FACULTY LAV 700 RIGHT CENTER	79.8	07/27/2021	
21-07-02728-015	148.1-212	07/01/2021	MENS LAV 700 SINK	9.26	07/27/2021	
21-07-02728-016	148.1-226	07/01/2021	ROOM 608 SINK	2.61	07/27/2021	
21-07-02728-017	148.1-235	07/01/2021	ROOM 612 REAR SINK NEAR EYEWASH	56.7	07/27/2021	
21-07-02728-018	148.1-244	07/01/2021	VISIT WOMENS LAV LEFT	81.1	07/27/2021	
21-07-02728-019	148.1-245	07/01/2021	VISIT WOMENS LAV LEFT CENTER	68.7	07/27/2021	
21-07-02728-020	148.1-246	07/01/2021	VISIT WOMENS LAV RIGHT CENTER	21.3	07/27/2021	
21-07-02728-021	148.1-250	07/01/2021	VISIT MENS LAV LEFT	16.3	07/27/2021	
21-07-02728-022	148.1-251	07/01/2021	VISIT MENS LAV LEFT CENTER	45.2	07/27/2021	
21-07-02728-023	148.1-252	07/01/2021	VISIT MENS LAV RIGHT	39.0	07/27/2021	

Method: EPA 200.8

Analyst: Ailea Cabatbat

Accreditation #: NY 11714

Reviewed By Authorized Signatory: *Melissa Kanode*

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



3860 California Road, Orchard Park, New York 14127
 PHONE (716) 312-0070 FAX (716) 312-8092
 WWW.STOHLENVIRONMENTAL.COM

Chain of Custody Document

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-148.1

Client: Sweet home

Contact: Steve Rozler

Building: High Schoool

Location: 1901 Sweet Home Rd, Buffalo, NY 14228

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
148.1-21	Boiler Room	S	
148.1-63	Womans Coach's Office	S	
148.1-67	Boys Phys Ed Locker Room 518 West	S	
148.1-70	Boys Visitor Locker Room 520 Left	S	
148.1-71	Boys Visitor Locker Room 520 Right	S	
148.1-72	Laundry Room Sink	S	
148.1-97	Girls Lav 300 Right Most	S	
148.1-98	Mens Faculty Lav 200 Left	S	
148.1-99	Mens Faculty Lav 200 Right	S	
148.1-101	Womens Faculty Lav 200 Center	S	
148.1-205	Room 716 Kitchenette	S	
148.1-207	Womens Faculty Lav 700 Left	S	
148.1-208	Womens Faculty Lav 700 Left Center	S	
148.1-209	Womens Faculty Lav 700 Right Center	S	
148.1-212	Mens Lav 700 Left	S	
148.1-226	Room 608 Sink	S	
148.1-235	Room 612 Rear Sink Near Eyewash	S	
148.1-244	Visit Womens Lav Left	S	

21-07-02728



Due Date:
 08/17/2021
 (Tuesday)
 AE

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Andrew Theal Print Name Andrew Theal Stohl Env: Andrew Theal Date: 7/1/2021

Relinquished By: Eric Henderson Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 7/6/2021

Received (Name / Lab): KT Harris Date: 7-20-21 Time: 10:45 AM

Sample Login (Name / Lab): Trace Bloom Date: 7/20/21 Time: 3:58 AM

Analysis (Name / Lab): Shela Cabot Date: 7/20/21 Time: 11:09 AM

Review (Name / Lab): Trace Bloom Date: 7/20/21 Time: 2 PM

QA/QC InterLAB Use: _____ Date: _____ Time: _____



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02722

Received Date: 07/20/2021
Reported Date: 07/27/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-148.2; Middle School; 4150 Maple Road; Amherst, NY 14226

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02722-001	148.2-2	07/01/2021	BY ROOM 159A	14.5	07/23/2021	
21-07-02722-002	142.2-33	07/01/2021	GYM LEFT	15.5	07/23/2021	
21-07-02722-003	148-2-113	07/01/2021	GIRLS LAV STAIRWELL 2 RIGHT	63.1	07/23/2021	

Method: EPA 200.8
Analyst: Ailea Cabatbat
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02716

Received Date: 07/20/2021
Reported Date: 07/27/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-148.3; Glendale Elementary School; 101 Glendale Dr; Tonawanda, NY 14150

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02716-001	148.3-11	07/01/2021	COPY ROOM 274	27.3	07/23/2021	
21-07-02716-002	148.3-13	07/01/2021	GIRLS LR 244 LEFT	20.5	07/23/2021	
21-07-02716-003	148.3-15	07/01/2021	BOYS LR 236	8.11	07/23/2021	
21-07-02716-004	148.3-40	07/01/2021	ROOM 312 SINK	63.4	07/23/2021	
21-07-02716-005	148.3-60	07/01/2021	ROOM 262 SINK	42.7	07/23/2021	
21-07-02716-006	148.3-68	07/01/2021	ROOM 265 SINK	55.7	07/23/2021	
21-07-02716-007	148.3-84	07/01/2021	ROOM 109 SINK	17.5	07/23/2021	
21-07-02716-008	148.3-92	07/01/2021	ROOM 114 SINK	46.6	07/23/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-07-02716

Project/Test Address: 2020L-148.3; Glendale Elementary School; 101
Glendale Dr; Tonawanda, NY 14150

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Ailea Cabatbat

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Submitted to: (Lab Name) EHS

STOHL Job # 2020L-148.3

Client: Sweet Home CSD Contact: Steve Rozler

Building: Glendale Elementary School Location: 101 Glendale Dr, Tonawanda, NY 14150

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)

X

Turnaround

20 Days

21-07-02716



Due Date:
08/17/2021
(Tuesday)
AE

Notes:

Please e-mail lab results to labs@stohlen.com

☒

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Stohl Env: Paul Nichols Date: 7/1/2021

Relinquished By: E. Henderson Jr. Print Name: Stohl Env: Eric Henderson Jr. Date: 7/6/2021

Received (Name / Lab): KTHARRIS K. J. J. Date: 7.20.21 Time: 10:33 AM

9 Login (Name / Lab): Troy Asanika, Bior Date: 7/27/21 Time: 8:50 AM

Name / Lab): AC/Alfred Albert Date: 7/23/21 Time: 11:04am

(Name / Lab): Naveen Date: 7/7/21 Time: 10am

QA/QC InterLAB Use: Date: Time:



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02720

Received Date: 07/20/2021
Reported Date: 07/27/2021
Sampled By: Andrew Theal
Tech Certification #:

Project/Test Address: 2020L-148.4; Heritage Heights Elementary School; 2545 Sweet Home Rd;
Buffalo, NY 14228

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02720-001	148.4-1	07/01/2021	OFC MAIL ROOM	1.82	07/23/2021	
21-07-02720-002	148.4-20	07/01/2021	BOYS LR	2.26	07/23/2021	
21-07-02720-003	148.1-23	07/01/2021	GIRLS LR	1.00	07/23/2021	

Method: EPA 200.8
Analyst: Ailea Cabatbat
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02724

Received Date: 07/20/2021
Reported Date: 07/27/2021
Sampled By: Andrew Theal
Tech Certification #:

Project/Test Address: 2020L-148.5; Maplemere Elementary School; 236 E Maplemere Rd; Amherst,
NY 14221

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02724-001	148.5-20	07/01/2021	ROOM 103	24.5	07/23/2021	
21-07-02724-002	148.5-21	07/01/2021	ROOM 101	28.8	07/23/2021	
21-07-02724-003	148.5-40	07/01/2021	ROOM 201 LAV	10.9	07/23/2021	
21-07-02724-004	148.5-62	07/01/2021	ROOM 212	13.1	07/23/2021	
21-07-02724-005	148.5-65	07/01/2021	ROOM 208	33.6	07/23/2021	
21-07-02724-006	148.5-79	07/01/2021	ROOM 110	3540	07/23/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-07-02724

Project/Test Address: 2020L-148.5; Maplemere Elementary School; 236 E
Maplemere Rd; Amherst, NY 14221

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Ailea Cabatbat

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



STOHL Job # 2020L-148.5

Location: 236 E Maplemere Rd, Amherst, NY 14221

20 Days

21-07-02724

AE

☒ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Archived / Released: QA/QC InterLAB Use: Date: Time:



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02732

Received Date: 07/20/2021
Reported Date: 07/29/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-148.6; Willow Ridge Elementary School; 480 Willow Ridge Dr; Buffalo,
NY 14228

Client Number:
33-5980

Laboratory Results

Fax Number:
716-312-8092

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02732-001	148.6-16	07/01/2021	ROOM 313 SINK	67.1	07/27/2021	
21-07-02732-002	148.6-18	07/01/2021	ROOM 315 SINK	16.8	07/27/2021	
21-07-02732-003	148.6-26	07/01/2021	ROOM 306 SINK	11.1	07/27/2021	
21-07-02732-004	148.6-40	07/01/2021	ROOM 204 SINK	26.8	07/27/2021	
21-07-02732-005	148.6-44	07/01/2021	ROOM 212 SINK	43.2	07/27/2021	
21-07-02732-006	148.6-47	07/01/2021	ROOM 207 SINK	52.9	07/27/2021	
21-07-02732-007	148.6-50	07/01/2021	ROOM 201 SINK	23.5	07/27/2021	
21-07-02732-008	148.6-85	07/01/2021	300 BOYS LAV FARTHEST FROM DOOR	1430	07/27/2021	
21-07-02732-009	148.6-89	07/01/2021	300 BOYS LAV CLOSEST TO DOOR	12.0	07/27/2021	
21-07-02732-010	148.6-92	07/01/2021	300 GIRLS LAV 3RD FARTHEST FROM DOOR	214	07/27/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-07-02732

Project/Test Address: 2020L-148.6; Willow Ridge Elementary School; 480
Willow Ridge Dr; Buffalo, NY 14228

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
----------------------	---------------------	--------------------	---------------------	-----------------------------	------------------	-----------------

Method: EPA 200.8

Analyst: Ailea Cabatbat

Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02739

Received Date: 07/20/2021
Reported Date: 07/29/2021
Sampled By: Paul Nichols
Tech Certification #:

Project/Test Address: 2020L-148.7; Dexter Terrace; 333 Dexter Terrace; Tonawanda, NY 14150

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02739-001	148.7-1	07/01/2021	ISS 3B FACING EXIT SOUTH	30.6	07/29/2021	
21-07-02739-002	148.7-2	07/01/2021	ISS 3B FACING BACK WALL NORTH	12.0	07/29/2021	
21-07-02739-003	148.7-3	07/01/2021	ISS 3B LAV	9.22	07/29/2021	
21-07-02739-004	148.7-4	07/01/2021	ISS 3C	18.7	07/29/2021	
21-07-02739-005	148.7-5	07/01/2021	ISS 3C LAV	249	07/29/2021	
21-07-02739-006	148.7-7	07/01/2021	SPECIAL ED BR SINK	8.39	07/29/2021	
21-07-02739-007	148.7-9	07/01/2021	ROOM 116 LAV	35.0	07/29/2021	
21-07-02739-008	148.7-10	07/01/2021	ROOM 118 LEFT	22.4	07/29/2021	
21-07-02739-009	148.7-12	07/01/2021	ROOM 120 LAV	27.8	07/29/2021	
21-07-02739-010	148.7-13	07/01/2021	CENTER BASE LAV	37.4	07/29/2021	
21-07-02739-011	148.7-14	07/01/2021	ROOM 230	31.9	07/29/2021	
21-07-02739-012	148.7-16	07/01/2021	CROSS HALL WOMENS LAV NEAR 216 LEFT	28.7	07/29/2021	
21-07-02739-013	148.7-17	07/01/2021	CROSS HALL WOMENS LAV NEAR 216 MIDDLE	16.7	07/29/2021	

Environmental Hazards Services, L.L.C

Client Number: 33-5980

Report Number: 21-07-02739

Project/Test Address: 2020L-148.7; Dexter Terrace; 333 Dexter Terrace;
Tonawanda, NY 14150

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02739-014	148.7-18	07/01/2021	CROSS HALL WOMENS LAV NEAR 216 RIGHT	75.2	07/29/2021	
21-07-02739-015	148.7-19	07/01/2021	CROSS HALL WOMENS LAV NEAR 221 LEFT	26.2	07/29/2021	
21-07-02739-016	148.7-24	07/01/2021	ROOM 214 LEFT	56.0	07/29/2021	
21-07-02739-017	148.7-25	07/01/2021	ROOM 214 RIGHT	58.2	07/29/2021	
21-07-02739-018	148.7-33	07/01/2021	ROOM 412 SINK NEAR FUME HOOD	27.6	07/29/2021	
21-07-02739-019	148.7-34	07/01/2021	ROOM 412 SINK EAST SIDE OF ROOM	42.6	07/29/2021	
21-07-02739-020	148.7-50	07/01/2021	ROOM 454 WEST	29.7	07/29/2021	
21-07-02739-021	148.7-51	07/01/2021	ROOM 454 NEAR FUME HOOD	21.3	07/29/2021	
21-07-02739-022	148.7-54	07/01/2021	ROOM 440 NORTH	60.7	07/29/2021	
21-07-02739-023	148.7-59	07/01/2021	CAFETERIA BOYS LAV LEFT	17.4	07/29/2021	
21-07-02739-024	148.7-63	07/01/2021	PENTHOUSE	171	07/29/2021	
21-07-02739-025	148.7-64	07/01/2021	118 RIGHT SINK	18.3	07/29/2021	

Method: EPA 200.8
Analyst: Ailea Cabatbat
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Chain of Custody Document

3860 California Road, Orchard Park, New York 14127
PHONE (716) 312-0070 FAX (716) 312-8092
WWW.STOHLENVIRONMENTAL.COM

Submitted to: (Lab Name) EHS

STOHL Job # 2020L-148.7

Client: Sweet Home CSD

Contact: Steve Rozler

Building: Dexter Terrace

Location: 333 Dexter Terrace, Tonawanda, NY 14150

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10) X

Turnaround

20 Days

Sample #	Location	Outlet Type	Time
148.7-1	ISS 3B - Facing Exit/South	S	4:35
148.7-2	ISS 3B Facing back wall/North	S	4:36
148.7-3	ISS 3B Lav	S	4:27
148.7-4	ISS 3C	S	4:38
148.7-5	ISS 3C Lav	S	4:39
148.7-7	Special Ed BR Sink	S	4:41
148.7-9	Room 116 Lav	S	4:41
148.7-10	Room 118 Left	S	4:43
148.7-12	Room 120 Lav	S	4:45
148.7-13	Center Base Lav	S	4:46
148.7-14	Room 230	S	4:47
148.7-16	Cross Hall Womens Lav - Near 216 Left	S	4:49
148.7-17	Cros Hall Womens Lav - Near 216 Middle	S	4:50
148.7-18	Cros Hall Womens Lav - Near 216 Right	S	4:51
148.7-19	Cros Hall Womens Lav - Near 221 Left	S	4:52
148.7-24	Room 214 Left	S	4:57
148.7-25	Room 214 Right	S	4:58
148.7-33	Room 412 Sink Near Fume Hood	S	5:03

21-07-02739



Due Date:
08/17/2021
(Tuesday)
AE

Notes:

Please e-mail lab results to labs@stohlenvironmental.com

☒ If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Paul Nichols Print Name Paul Nichols Stohl Env: Paul Nichols Date: 7/1/2021

Relinquished By: E. Henderson Print Name Eric Henderson Jr. Stohl Env: Eric Henderson Jr. Date: 7/7/2021

Received (Name / Lab): KTHARRIS K. Harris Date: 7.20.21 Time: 10:47AM

Sample Login (Name / Lab): Tracey Brown Date: 7/27/21 Time: 9:05AM

Analysis (Name / Lab): AE Alred Alred Date: 7/29/21 Time: 11:00AM

QA/QC Review (Name / Lab): Meluh Date: 7/29/21 Time: 4pm

Archived / Released: _____ QA/QC InterLAB Use: _____ Date: _____ Time: _____



Environmental Hazards Services, L.L.C.
7469 Whitepine Rd
Richmond, VA 23237
Telephone: 800.347.4010

Lead in Drinking Water Analysis Report

Client: Stohl Environmental
3860 California Road
Orchard Park, NY 14127

Report Number: 21-07-02723

Received Date: 07/20/2021
Reported Date: 07/27/2021
Sampled By: Andrew Theal
Tech Certification #:

Project/Test Address: 2020L-148.8; Service Center; 1741 Sweet Home Rd; Buffalo, NY 14228

Client Number:
33-5980

Fax Number:
716-312-8092

Laboratory Results

Lab Sample Number	Client Sample ID	Collection Date	Collection Location	Concentration ug/L (ppb)	Analysis Date	Narrative ID
21-07-02723-001	148.8-5	07/01/2021	HAND SINK EAST	18.5	07/23/2021	
21-07-02723-002	148.8-22	07/01/2021	2 KETTLE SIDE RIGHT	4.38	07/23/2021	

Method: EPA 200.8
Analyst: Ailea Cabatbat
Accreditation #: NY 11714

Reviewed By Authorized Signatory:

Melissa Kanode

Missy Kanode

QA/QC Clerk

Sample Results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 ppb.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 ppb. The results herein conform to NELAC standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, etc., were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

LEGEND ug/L= micrograms per liter ppb = parts per billion



Submitted to: (Lab Name) EHS

STOHL Job # 2020L-148.8

Client: Sweet Home CSD

Contact: Steve Rozler

Building: Service Center

Location: 1741 Sweet Home Rd. Buffalo, NY 14228

LEAD

Water by SM 19, 21 - 23 3113B (-04, -10)	X
--	---

Turnaround

20 Days

21-07-02723



Due Date:
08/17/2021
(Tuesday)
AE

Notes:

Please e-mail lab results to labs@stohlenv.com

☒ If checked, also e-mail results to: Ehenderson@StohlEnv.com

Sampled By: Andrew Theal Print Name Stohl Env: Andrew Theal Date: 7/1/2021

Relinquished By: E. Henderson Jr. Print Name Stohl Env: Eric Henderson Jr. Date: 7/7/2021

Received (Name / Lab): ETHAN KIRK Date: 7.20.21 Time: 10:40 AM

Sample Login (Name / Lab): Tami Bloom / Lab A Date: 7/7/21 Time: 8:53 AM

Analysis (Name / Lab): Alleg (EcoLab) Date: 7/22/21 Time: 1:20 pm

QA/QC Review (Name / Lab): Nedra Date: 7/27/24 Time: 10am

Archived / Released: QA/QC InterLAB Use: Date: Time: